


CCFM Studies



Each channel of CCFM measure for crate i ($i=0,7$) :

$$T_i^{\text{return}} - T^{\text{stop}} = \Delta T_i$$



For $i \neq j$ $\Delta T_{i,j} =$

$$T_i^{\text{return}} - T_j^{\text{return}} - \langle \Delta T_{i,j} \rangle$$



vs time is shown.

If no external effect detected this should have been a constant.


CCFM Studies



CCFM Studies



CCFM Studies





- Provided the 12ps/count is confirmed by dedicated measurement to be taken during shutdown preliminary analysis say crate to crate stop signal variation is within spec.
- Some hints of an effect of temperature differences between East and West side of the detector.

CCFM software status

- VxWorks version exists and tested (need some cleanup)
- Need to understand which is the correct time delay to use reading out the board(see plots) and the source of the effect observed (Italians investigating this)
- When code is in FER should start analyzing this data more consistently (need help!)


CCFM mean ΔT_i as a function of delay



Conclusions

- Software to be included in FER in $O(1 \text{ week})$
- During the shutdown we propose to add a cable of known length to one of the most accessible LCF to make sure we understand what a “count” is
- People in Italy investigating this “delay” dependence of the CCFM measurements and working on a new design for the CCFM board.

CCFM Studies



Each channel of CCFM measure for crate i ($i=0,7$) :

$$T_i^{\text{return}} - T^{\text{stop}} = \Delta T_i$$



For $i \neq j$ $\Delta T_{i,j} =$

$$T_i^{\text{return}} - T_j^{\text{return}} - \langle \Delta T_{i,j} \rangle$$



vs time is shown.

If no external effect detected this should have been a constant.


CCFM Studies



CCFM Studies



CCFM Studies





- Provided the 12ps/count is confirmed by dedicated measurement to be taken during shutdown preliminary analysis say crate to crate stop signal variation is within spec.
- Some hints of an effect of temperature differences between East and West side of the detector.

CCFM software status

- VxWorks version exists and tested (need some cleanup)
- Need to understand which is the correct time delay to use reading out the board(see plots) and the source of the effect observed (Italians investigating this)
- When code is in FER should start analyzing this data more consistently (need help!)

CCFM mean ΔT_i as a function of delay



Conclusions

- Software to be included in FER in $O(1 \text{ week})$
- During the shutdown we propose to add a cable of known length to one of the most accessible LCF to make sure we understand what a “count” is
- People in Italy investigating this “delay” dependence of the CCFM measurements and working on a new design for the CCFM board.